

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No.....19.....

Date:..12/01/2021.....

It is certified that an inspection team headed by **Aakash Sahni, Assistant Engineer, P.H.E.D , Samastipur** (Name of Officers with Designation) From **Public Health Subdivision, Samastipur** (Name of Department/Office) inspected the **Gurukul Senior Secondary School, At- Dadpur, P.O-Rahamatpur Chaknoor, Distt-Samastipur, Bihar-848101** (Name & Address of the School) on **08.01.2021** and found that the **Gurukul Senior Secondary School** (Name of School) has Safe drinking water for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T Govt.

The above valid for a period of:- **One year only**

Signature with Seal..........

Name: **Aakash Sahni**

Designation: **Sub Divisional Officer**
P.H. Sub. Division, Samastipur

To,

Chairman,
Gurukul Senior Secondary School,
At- Dadpur, P.O- Rahamatpur Chaknoor,
Distt-Samastipur, Bihar-848101
(Name & Address of the Institution)

**Government of Bihar
Public Health Engineering Department**

District Name: Samastipur

Month-January 2021

Sl. No.	Block	Panchyat	Village	Location of Source	Parameters												Remarks
					pH	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	
1	Samastipur	RahmatpurChaknur	Dadpur	Gurukul Sr. Sec.School	7.4	546	391	168	40	16	24	152	0.4	BDL	15	0.6	safe
Desirable Limit*					6.5-8.5	-	500	300	75		250	200	1.0	45	200	1.0	
Permissible Limit* in absence of alternate source					NR	-	2000	600	200		1000	600	NR	NR	400	1.5	

Bimal Kumar
11/01/21
Lab Assistant

Revan
11.01.2021
Chemist

ACP 120
11/01/2021
Executive Engineer
P.H. Division
Samastipur